

June 3, 2005

Mr. L. William Pearce
Vice President
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

SUBJECT: BEAVER VALLEY POWER STATION, UNITS 1 AND 2 - REQUEST FOR
ADDITIONAL INFORMATION (RAI) RELATED TO GENERIC LETTER 2004-02,
"POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP
RECIRCULATION AT PRESSURIZED-WATER REACTORS"
(TAC NOS. MC4665 AND MC4666)

Dear Mr. Pearce:

By letter dated March 4, 2005, FirstEnergy Nuclear Operating Company (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Beaver Valley Power Station, Units 1 and 2. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

If you have any questions, please call me at (301) 415-1402.

Sincerely,

/RA/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosure: Request for Additional Information

cc w/encl: See next page

June 3, 2005

Mr. L. William Pearce
Vice President
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

SUBJECT: BEAVER VALLEY POWER STATION, UNITS 1 AND 2 - REQUEST FOR ADDITIONAL INFORMATION (RAI) RELATED TO GENERIC LETTER 2004-02, "POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS" (TAC NOS. MC4665 AND MC4666)

Dear Mr. Pearce:

By letter dated March 4, 2005, FirstEnergy Nuclear Operating Company (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Beaver Valley Power Station, Units 1 and 2. The GL requested the licensee perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL.

The NRC staff has completed its preliminary review of your response and has determined it needs additional information requested in the enclosure to complete our review.

This RAI requests additional information about your overall plans and schedules and not any information on detailed plans or extensive analyses. In light of this, please provide the additional information requested in the enclosure within 45 days of receipt of this letter.

If you have any questions, please call me at (301) 415-1402.

Sincerely,

/RAI/

Timothy G. Colburn, Senior Project Manager, Section 1
Project Directorate I
Division of Licensing Project Management
Office of Nuclear Reactor Regulation

Docket Nos. 50-334 and 50-412

Enclosure: Request for Additional Information

cc w/encl: See next page

DISTRIBUTION:

PUBLIC

RidsAcrsAcnwMailCenter

RidsNrrLADBaxley

RidsNrrDlpmDpr

PDI-1 R/F

RidsNrrDlpmLpdi1 (RLaufer)

RidsRgnlMailCenter

RidsNrrDssaDpr

RidsOgcRp

RidsNrrPMTColburn

DCullison/DSolorio

MWebbRidsNrrLAMO'Brien

Accession No.: ML051530267

*RAI input from SPLB without any major change

| | | | | | |
|--------|-------------------------|-----------|---------------------|----------|-------------------------|
| OFFICE | PDIV-1/PM PDIII-2/PM | PDIV-1/LA | DSSA/SPLB/SP | PDI-1/PM | PDIV-1/SC PDIII-2/SC |
| NAME | MWebb/JHopkins | DBaxley | DCullison/DSolorio* | TColburn | DTerao/ GSuh |
| DATE | 6/2/2005 | 6/2/05 | 5/23/05 | 6/3/05 | 6/3/05 |

OFFICIAL RECORD COPY

Beaver Valley Power Station, Unit Nos. 1 and 2

cc:

Mary O'Reilly, Attorney
FirstEnergy Nuclear Operating Company
FirstEnergy Corporation
76 South Main Street
Akron, OH 44308

FirstEnergy Nuclear Operating Company
Regulatory Affairs/Performance
Improvement
Larry R. Freeland, Manager
Beaver Valley Power Station
Post Office Box 4, BV-A
Shippingport, PA 15077

Commissioner James R. Lewis
West Virginia Division of Labor
749-B, Building No. 6
Capitol Complex
Charleston, WV 25305

Director, Utilities Department
Public Utilities Commission
180 East Broad Street
Columbus, OH 43266-0573

Director, Pennsylvania Emergency
Management Agency
2605 Interstate Dr.
Harrisburg, PA 17110-9364

Ohio EPA-DERR
ATTN: Zack A. Clayton
Post Office Box 1049
Columbus, OH 43266-0149

Dr. Judith Johnsrud
National Energy Committee
Sierra Club
433 Orlando Avenue
State College, PA 16803

J. H. Lash, Plant Manager (BV-IPAB)
FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Post Office Box 4
Shippingport, PA 15077

Rich Janati, Chief
Division of Nuclear Safety
Bureau of Radiation Protection
Department of Environmental Protection
Rachel Carson State Office Building
P.O. Box 8469
Harrisburg, PA 17105-8469

Mayor of the Borough of Shippingport
P O Box 3
Shippingport, PA 15077

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Resident Inspector
U.S. Nuclear Regulatory Commission
Post Office Box 298
Shippingport, PA 15077

FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
ATTN: R. G. Mende, Director
Work Management (BV-IPAB)
Post Office Box 4
Shippingport, PA 15077

FirstEnergy Nuclear Operating Company
Beaver Valley Power Station
Mr. B. F. Sepelak
Post Office Box 4, BV-A
Shippingport, PA 15077

REQUEST FOR ADDITIONAL INFORMATION
REGARDING GENERIC LETTER 2004-02,
“POTENTIAL IMPACT OF DEBRIS BLOCKAGE ON
EMERGENCY SUMP RECIRCULATION AT PRESSURIZED-WATER REACTORS”
FIRSTENERGY NUCLEAR OPERATING COMPANY
BEAVER VALLEY POWER STATION, UNITS 1 AND 2
DOCKET NOS. 50-334 AND 50-412

By letter dated March 4, 2005, FirstEnergy Nuclear Operating Company (the licensee) provided the 90-day response to U. S. Nuclear Regulatory Commission (NRC) Generic Letter (GL) 2004-02 for Beaver Valley Power Station, Units 1 and 2. The GL requested that addressees perform an evaluation of the emergency core cooling system and containment spray system recirculation functions in light of the information provided in the GL and, if appropriate, take additional actions to ensure system function. Additionally, addressees were requested to submit to the NRC the information specified in the GL. The staff has completed its preliminary review of your response and has determined it needs the following additional information to complete our review:

As a result of the review of the 90-day responses for all licensees and recent discussions with industry, the staff is concerned that some licensees may be delaying the evaluation of chemical and downstream effects until after the September 1, 2005, due date for the next response to the GL. This would result in an incomplete response and is not in accordance with the schedule in the GL. Your 90-day response indicated that your analysis will be completed by September 1, 2005, but did not discuss the evaluation of chemical and downstream effects. Although the GL did not specifically request that the evaluation of chemical and downstream effects be discussed in the 90-day response, please discuss your plans and schedule for evaluating chemical and downstream effects and verify whether your September 1, 2005, response will include an evaluation of these effects.

ENCLOSURE